Information Request TEC-3-17

Referring to Mr. Salamone's Rebuttal Testimony at p. 6, lines 18-19, please define non-coincident peak for a substation.

Response

The non-coincident peak demand of a substation is the maximum peak demand of the individual substation, based upon the coincident peaks of all circuits served by the substation.

Information Request TEC-3-20

Referring to Mr. Salamone's Rebuttal Testimony at p. 7, lines 5-7, please provide documentation for the diversity factors for substations in the 92% to 98% range.

Response

Please refer to the response to Information Request JS-NSTAR-1-5.

Information Request TEC-3-23

For each of the NSTAR companies, please supply a list of the distribution substations, their location, the maximum capacity for each (summer and winter ratings, if applicable), and maximum summer and winter load on each. Please provide this information on an Excel spreadsheet.

Response

Please refer to the response to Information Request AG-1-10 and AG-1-10(Supp).